

SUCCESS STORIES

BACKGROUND

Application:

Power Generation

Location:

TN, USA

Site:

525 MW Gas-Fired Combined Cycle Plant
with a GE D11 Steam Turbine

PROBLEM

Following an extended outage, the Plant Operator discovered that the phosphate ester-based fire-resistant fluid (FRF) used in the Steam Turbine's control system had become extremely acidic. With an acid number that was 6x higher than the application's maximum in-service limit, the end user expected that they would need to replace the entire reservoir of costly synthetic fluid.

SOLUTION

An SVR[®] Lubricant Conditioning skid employing ICB[®] FRF filters was installed on the Steam Turbine's control system.

RESULTS

By regularly changing their ICB FRF filters at monthly intervals, the Power Plant operator was able to remove acids that were present, restoring their FRF's acid number to acceptable levels. As an additional benefit of ICB conditioning, the FRF's MPC varnish potential and resistivity were also brought back to within specification. Once the FRF was restored, continued oil conditioning prevented varnish and acids from accumulating again. Oil condition-related failures are a thing of the past at this site as the result of SVR/ICB FRF and the Plant enjoyed significant savings as the result of no longer needing to replace their costly, synthetic FRF.

TEACHING THE WORLD A BETTER WAY.



Eliminate lubricant-related failures with our Lubricant Chemistry Management solutions.

